



88 Empire Drive • St. Paul, Minnesota • 55103  
 (651) 642-1150 • fax (651) 642-1239

## VOC Content Test Certificate

January 28, 2013

Supplier: Hilti Entwicklungsgesellschaft mbH  
 BU Anchors  
 Hiltistrasse 6  
 86916 Kaufering  
 GERMANY

Sample Description: Hilti HIT-ICE

Date Tested: January 25, 2013

Test Method: SCAQMD method 304-91 "Determination of Volatile Organic Compounds (VOC) in Various Materials" as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data:

Specification	Product
<b>LEED 2009 (LEED 3.0)</b> <b>LEED 2.2</b> IEQ-4.1: Low-Emitting Materials – Adhesives and Sealants	<b>Hilti</b> <b>HIT-ICE</b>
<b>Green Building Council of Australia</b> Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
<b>Architectural Sealant;</b> <b>VOC Limit: 250 g/L</b>	<b>Product contains: 16 g/L of VOC</b>

---

Tom Barrett  
 Vice President/Strategic Analytical Services

---

Scott Creekmur  
 Chemist II